



Alabama State Port Authority
Addendum to R&P or Specification Booklet

Project Name Berth 2 Fender Refurbishment

Project No. 11089 **Task No.** 01 **Addendum No.** 2

To: Prospective Bidders **Date:** 5/31/2022

The following items are clarifications to questions received. These items are hereby included in the bid documents by this addendum.

Item	Description
1.	<p>Question: Is it acceptable to sawcut an access port in the existing dock to be able to install the new threaded rods. Dock deck access port would be formed and repoured with 5000 psi concrete once threaded rods installed. The concern is that the face of the dock extends to the water so it isn't clear how the back of the dock will be accessible to add nuts to the threaded rod.</p> <p>Answer: The intention is to remove the threaded rods from the sleeves, then to replace the rods and the nuts. There is boat access to the back of the dock at the South end of Pier 2.</p>

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.

Project Manager:

Matthew Thomas 5/31/2022
 Matthew Thomas, E.I. Date
 Civil Engineer