



Alabama State Port Authority
Addendum to R&P or Specification Booklet

Project Name Terminal Railway Office Addition/Renovation

Project No. 11012 **Task No.** 02 **Addendum No.** 4

To: Prospective Bidders

Date: 09/07/2022

The following items are clarifications to questions received. These items are hereby included in the bid documents by this addendum.

Item	Description
1.	Contractor shall include a termite treatment with Bid.
2.	Contractor shall be required to apply a fluid applied thermal barrier coating, No-Burn or equal, to spray foam located above suspended ceiling.

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.