



Alabama State Port Authority
Addendum to R&P or Specification Booklet

Project Name McDuffie Warehouse

Project No. 10861 **Task No.** 02 **Addendum No.** 3

To: Prospective Bidders

Date: 9/15/2022

The following items are clarifications to the bid documents. These items are hereby included in the bid documents by this addendum.

Item	Description
1.	Clarification: The weight of the new warehouse fans is not included in the 8psf collateral load. The weight of the fans is an additional load.
2.	Clarification: Manufacturer may adjust design of mezzanine. Design shall support the required loads with the corresponding max deflections designated in the drawings and specifications. Design shall be stamped by a professional engineer licensed in the state of Alabama.

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.