



**Alabama State Port Authority**  
**Addendum to R&P or Specification Booklet**

**Project Name** HEAD OF SLIP C LIGHT POLE DAMAGE 11.21.22

**Project No.** 11222      **Task No.**      **Addendum No.** 2

**To:** Prospective Bidders      **Date:** 3/1/2023

The following items are clarifications to questions received. These items are hereby included in the bid documents by this addendum.

Item	Description
1.	The R&P implied we were reusing the same wire. This is to be corrected. We will need to pull new wire from the panel to the first pole and new wire to the next pole. We are concerned that the existing wire was likely damaged when they knocked the pole down.

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.

**Project Manager:**

<i>Matthew Thomas</i>	3/1/2023
Matthew Thomas, P.E.	Date