



**Alabama State Port Authority**  
**Addendum to R&P or Specification Booklet**

**Project Name** Pier 6 and 7 East Roof Replacement

**Project No.** 11389      **Task No.** 01      **Addendum No.** 2

**To:** Prospective Bidders      **Date:** 3/19/2024

The following items are clarifications to questions received. These items are hereby included in the bid documents by this addendum.

Item	Description
1.	Question: What does the port use for their termite control?  Answer: The following shall be used for termite treatment at ASPA: Above ground treatment on active termites is Termidor. Treatment used on new timber and non-active termite areas can be Bora-care or Tim-bor.

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.

**Project Manager:**

*Mike Thompson*      3/19/2024  
 Mike Thompson, Civil Engineer      Date  
 Project Engineer