



Alabama State Port Authority
Addendum to R&P or Specification Booklet

Project Name: Pier B South Replacement

Project: 11283 Task 02

ADDENDUM No. 03

To: Prospective Bidders

Date: 9/08/2025

This Addendum contains the following information and becomes a part of the Bid Package.

Item	Description
1	Responses to bid RFIs

Please indicate your receipt of this addendum by adding the addendum number in the appropriate place in your Requisition & Proposal or Specification Book.

Project Manager:

Matthew Thomas

Matt Thomas, P.E.
Facilities Engineer

9/08/25

Date



Alabama State Port Authority

Project Name Pier B South Replacement

Location Mobile, AL

Project # 11283 **Task #** 02

September 8, 2025

1 | Page

Addendum No. 03

Response to RFIs

1. Due to supplier information that Stay-In-Place Forms are not sufficient to support the loads of the concrete deck, can the deck be poured in two separate vertical lifts?

Response: No, refer to SD-13 note 8 to fill the flutes with EPS Foam to limit the concrete weight during construction. This is a "Contractor's Option" and the size of forms may be increased as the Contractor deems necessary.

2. Due to the complexity and sequencing of the work, can the base contract duration be extended by 6 months to a total of 910 Calendar days?

Response: No

End Clarifications and RFI Responses